

APPLICATION No.: 17408

TAP CLEARED 8346-1632

LOCATION: 301 Tinkham N.S., W. of Brook

OWNER: Edmond A. Bonneau

MEASURES: 5/8"

W from	Brook	105.6 ft.
S from N line	Tinkham	9.8 ft.
E from W line	house	4.9 ft.

January 17, 1955 Renewed from property line to inside the cellar.
Main shutoff renewed.

12 ft. of 3/4" copper tubing

Stock supplied and installed by owner's plumber.

Nov. 18, 1983 - Renewed 1/2 ft. outside curb stop to
property line.

7 1/2 ft. - 3/4" copper tubing

2 - 3/4" copper to copper cplgs.

1 - 3/4" curb stop 1 stop box

1 - 5/8" x 3/4" lead to copper adaptor XXS

Aug. 21, 1996: Renewed from main to a point lft

Stock: 1ft 3/4" copper tubing 1-3/4x5/8 lead-cop adapt.xs

1- 3/4 x 5/8 Fig 413

=====

March 23, 2003: Renewed from main to curb stop; 24 ft. - 3/4" copper
tubing; 1 - 3/4" curb stop; 1 - Caldwell stop box; 1 - 5/8x3/4 Fig.
413; tap reamed

7/17/07 Re-set curb stop (box lying down) Monty

DATE

BEF.

AFT.

REMARKS

8/21/96: tap reamed

3/24/03 830 AM 2003-130 0325

[illegible]

CHARGE OUTS

[illegible]

APPLICATION No.: #33214

TAP CLEARED

LOCATION: 301 Tinkham St., W x Brook St. 105 ft.

DATE

BEF.

AFT.

REMARKS

OWNER: Andrew Cronin

31-313

MEASURES: 2" F.S. Copper March 29, 2006

FIRE SUPPLY

W x W line Brook St.	110.0 ft.
S x N line Tinkham St.	7.0 ft.
E x W line house	2.0 ft.
W x E line house	25.0 ft.
S x S line house	16.6 ft.

[illegible]

CHARGE OUTS

[illegible]