

APPLICATION No.: 17413 5/8"

TAP CLEARED

LOCATION: 224 Church St.

OWNER: Joseph Dupre

MEASURES:

5/8"

S from	Query	153.9 ft.
W from E line	Church	6.0 11.0 ft.
S from N line	House	14.3 10.8 ft.
W x front step		6.5 ft.

DATE

BEF.

AFT.

REMARKS

9/22/60

reamed

4/8/99 1999/507506

Sept. 22, 1960 Renewed from main to property line:
 42 ft. of 3/4" copper tubing 3/4" copper stop
 3/4"x3/4" cop. to I.F. coupling, fig 413
 3/4" lead to copper coupling - Ford 1-c.i. stop box bottom
 lead left in ground

Dec. 7, 1998 Owner called concerned about lead inside. Olejarz checked punch 12 ft.
 Owner will call back if requesting renewal.

Jan. 6, 1999 Owner had lead sample taken - High lead count. Will come in to sign renewal cards to have
 work done in spring.

4-8-99 Renewed from property line into cellar.

Stock: 14 ft. - 3/4" Copper tubing, 1 - 3/4" x 3/4" cop to
 cop cplg., comp.

METER HISTORY

CHARGE OUTS

[illegible]