

APPLICATION No.: 17420

TAP CLEARED

LOCATION: 1742 ACUSHNET AVE N.E. COR EUGENIA

OWNER: JACOB YARTZMAN

MEASURES:

3/4"

E FROM ACUSHNET AVE

64.6 ft

S FROM N LINE EUGENIA ST

8.9 ft

W FROM E LINE BLDG

4.0 ft

April 10, 1997:

lead serv. replacement

Renewed from main to prop line

Stock: 32.0ft 3/4" copper tubing 1-3/4" curb stop

1- Caldwell stop box 1-3/4x5/8 lead-cop adapt.xxs

1- 3/4 x 3/4 FIG 413

=====

DATE

BEF.

AFT.

REMARKS

4/10/97: tap reamed

INACTIVE SER

METER HISTORY

[illegible]

CHARGE OUTS

LOCATION: 1742 Acush. Ave. N.E. Cor. Eugenia

DATE

BEF.

AFT.

REMARKS

OWNER: Jacob Yartzman

10/4/84 tap reamed

MEASURES: 3/4"

E from Acushnet Av. 64.6 ft.

S from N line Eugenia 8.9 ft.

W from E line Bldg. 4.0 ft.

Dec. 10, 1958 Service raised 1 C.I. stop box, comp.

Oct. 4, 1984: Renewed from main to a point 5.0 ft.

Stock: 5 ft. 3/4" copper tubing 1 3/4 x 3/4 lead
to cop adapt. XXS 1 3/4 x 3/4 Fig. 413

10/21/86: Renewed from 1/2' outside curb stop to a point 3.0 ft.

Stock: 3.0 ft. 3/4" copper tubing 1 - 3/4" curb stop

1 - Caldwell stop box 2 - 3/4 x 3/4 lead to cop adapt. xxs.

=====

Check out by Snyg 3/10/89 this service feeds
3 or 4 different stores. Photo store complaining
not enough pressure to run equipment.

METER HISTORY

CHARGE OUTS

[illegible]