

APPLICATION No.: 17422

LOCATION: 185-187 Nash Rd. N.S. W. of Acushnet Ave.

OWNER: Elisabeth McCarty

MEASURES: $5/8''$

W from

Acushnet Ave.

169.9 ft.

S from N line

Nash Rd.

9.3 ft.

E from W line

House

10.4 ft.

Aug. 23, 1977: Renewed 6" outside curb stop to 4 ft. inside curb stop. 4½ ft.-¾" copper; ¾" curb stop; 2-5/8" x ¾" lead to cop. adapt. XS; Caldwell stop box

9-17-98 Renewed from main to property line. 41ft. 3/4" Copper tubing, 1 - 3/4" Curb Stop, 1 - Caldwell Stop Box, 1 - 5/8" x 3/4" lead to cop. adapt. XS, 1 - 5/8" x 3/4" Fig. 413. D.W. White to maintain trench.

1" Copper Service

05/24/2018 Lead Service Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 60

Distance main to curb stop (Ft) N/A

Distance curb stop to meter (ft) 19.5

Distance from curb face to curb stop (ft) 3.0

Depth of service (ft) 4

Total length of new pipe installed (ft)	22.5
---	------

Curb stop replaced: No, Corporation Replaced: NO

Ball valve replaced: yes size 1"

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

9-17-98 Tap reamed

METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS
5-13-66		5/8	Empire T 12	9538307					

CHARGE OUTS

