

APPLICATION No.: 17445 5/8"

TAP CLEARED F 4229 V

LOCATION: #2 Viall St. S.E. Cor. Cove St.

OWNER:

MEASURES: 5/8"

S from	Cove	7.6 ft.
W from E line	Vaill	8.6 ft.
S from N line	Gatage	7.6 ft.

Mar. 3, 1980: Renewed from 1 ft. outside curbstop to existing lead.

18 ft.-3/4" copper (9' ins.)

2-5/8" x 3/4" lead-cop. adapt. XXS

1-3/4" curb stop

1-Caldwell stop box

- - - -

June 17, 1981: Renewed from main to apoint 3 ft. from main.

3 ft.-3/4" copper

1-3/4" x 3/4" Fig. 413 Tap reamed

1-5/8" x 3/4" lead-cop. adapt. XXS

- - - -

4-13-99 Renewed from main to property line. Stock:

28 ft. - 3/4" Copper tubing, 2 - 3/4" Curb Stop

1 - Caldwell Stop Box, 1 - 3/4" x 3/4" cop to cop cplg.,

comp. Second curb stop at 12 ft. east from main.

The copper to copper is 1 ft. from main.

DATE

BEF.

AFT.

REMARKS

JUN 17 1981

Reamed

8/2/86: TAP REAMED-plugged from
cement liners. Disconnected &
connected existing copper.

OK ELECT. 4-12-99/1999/600403

[illegible]

CHARGE OUTS

82

✓

OWNER: A & K Okolski

MEASURES: 5/8"

* 82 PER ASSESSOR'S

(NOTE NO ADDRESS ASSIGNED)

S from	Cove	7.6 ft.
W from E	Viall	8.6 ft.
S from N	Garage	7.6 ft.

Mar. 3, 1980: Renewed from 1 ft. outside curbstop to existing lead.
18 ft.-3/4" copper (9' ins.)
2-5/8" x 3/4" lead-cop. adapt. XKS
1-3/4" curb stop
1-Caldwell stop box

1999 2000 2001 2002

[illegible]

CHARGE OUTS

[illegible]