

APPLICATION No.: 17522

TAP CLEARED

LOCATION: 255 Mt. Pleasant S.W. Cor. Sawyer

OWNER: F Minkin

MEASURES: 1"

| | | |
|---------------|------------------|--------------------|
| S from | Sawyer | 20.6 ft. |
| E from W line | Mt. Pleasant 3.5 | 7.5 ft. |
| S from N line | House | 8.8 ft. |

1956 Contractor installed 8" main on east side.
Relocated service from 30" main and tapped into 8".
Copper from west side of 30" main to 8" main.

AUG 21 1981

Renewed service from the main to the ~~property line~~. curb stop.

22.0 ft. - 3/4" copper

1- 3/4" curb stop 1- Caldwell stop box

1- Fig. 413 1 1/4" x 1" Tap reamed

Note: No saddle used on transite pipe.

6-15-93 POOR PRESSURE - WOULD LIKE LEAD
REPLACED SAYS HOUSE BACK 20 FT+ WILL CAN
BACK IN JULY TO REPLACE PORCH + WILL THINK
ABOUT REPLACING! DOES NOT WANT PRESSURE
CHECKED @ THIS TIME.

9-14-2000 Renewed from curb stop to ins. cellar. Stock:
(29 ft. ins. prop. line) Stock: 33 tf. 1" Copper tubing

DATE

BEF.

AFT.

REMARKS

AUG 21 1981

Reamed

9/14/00 2000 3807529

[illegible]

CHARGE OUTS

[illegible]