

APPLICATION No.: 17528

## TAP CLEARED

LOCATION: 145 Highland N. W. Cor. Potter

OWNER: Geo N Milligan

MEASURES:

3/4"

W from

Highland

15.1 ft.

S from N line

Potter

6.8 ft.

W from E line

house

5.4 ft.

1/16/87: Repaired 4ft. south of curb stop to 7ft. south of curb stop. Had to shut down main. Broken by Bill Smith  
Stock: 2-3/4x5/8 lead to cop adapt. xxs. 3ft. 3/4" copper tubing. Repaired by Smith  
=====

2/5/97: Renewed from 1/2' outside curb stop to a point 4.5 ft. Stock  
5 ft. 3/4" copper tubing, 1-3/4" curb stop, 1- #1 Caldwell stop box,  
2- 5/8x3/4 lead to cop. adapt. xxs

11-17-98 Renewed from main to inside cellar .(5 ft. prop.  
line) Stock: 33 ft. - 3/4" Copper tubing, 1 - 3/4" Curb  
Stop, 1 - 3/4" x 1" Fig. 413.

DATE

BEF.

AFT.

REMARKS

2/5/98

980602900

8/20/98

98340 1588

11-17-98 Tap reamed

[illegible]

## CHARGE OUTS

[illegible]