

117 & 143

APPLICATION No.: 17548

TAP CLEARED



LOCATION: ~~111~~ King W.S. opp. Central Ave.

OWNER: Firestone Cotton Mill

MEASURES: 6" C.I. 2-21-20  
Darling gate I. box  
N from N line Central Ave. 23.4 ft.  
E from W line King 7.2 ft.  
240 ft. C.I. pipe including specials

6/7/99 Water Dept. installed a 6" GV (Muel) N x Central Ave.  
1st. coupling W x E line King St. 9.0 ft.  
2nd. coupling W x E line King St. 13.0 ft.

6" Muel Gv  
W x E line King St. 11.2 ft. ON  
N x N line Central Ave. 24.5 ft.

Stock: 1 - 6" Muel GV RS; 36" 6" DI pipe; 2 - 6" Smith-Blair cast  
cplg. 441; Foreman: M Rose, III

7/5/99 Removed & installed 6" DI dom. service for Chamberlain Mfg  
from new existing 6" gate valve to property line. 38.0 ft. Cont.  
took over inside property & building. Main was flushed from chlorine  
sample taken was okay to turn service on 7/13/99

Measures of gate valve: N x N line Central Ave. 25.0 ft.  
W x E line King St. 12.0 ft.

Bento

TURN OVER FOR MORE INFO/WORK DONE

DATE

BEF.

AFT.

REMARKS

6-7-99 1999 2400 626



[illegible]

## CHARGE OUTS

[illegible]

SHAW

#17548

CENTRAL  
AVE

8" MAIN

KING ST

1" Blow-off

38 ft

6" DI DOMESTIC

7-5-99 REMOVED & INSTALLED 6" DI DOM.  
SERVICE FOR CHAMBERLAIN MFG. FROM NEW  
EXIST 6" GATE VALVE TO PROP. LINE 38 ft.  
CONTRACTOR TOOK-OVER INSIDE PROPERTY & BUILDING.  
MAIN WAS FLUSH FROM CHLORINE - SAMPLE WAS TAKEN  
WAS OK. TO TURN SERVICE - ON. 7-13-99

MEASURES GATE VALVE: N x N LINE CENTRAL AVE 25 ft  
W X E LINE KING ST 12 ft

E X SIDE SIDEWALK CUT 16 x 4'  
W X SIDE SIDEWALK 10 x 7' } BLACKTOP

STREET CUT: 28' x 4' WARRENITE