

APPLICATION No.: 17623

TAP CLEARED

LOCATION: 1701-1719 Acushnet Ave WS from Nash to Whitman

DATE

BEF.

AFT.

REMARKS

OWNER:

31-313

MEASURES:

W from Acushnet Ave 62.0'  
N from S line Whitman 8.7'  
E from W line bldg 12.0'

1-10-84 Tap ream

1" COPPER

5-30-2018: Lead service line replacement program

Phase 1: TYPE: CU, Diameter 1, Water Pressure 70

Contractor P. Gioioso

Distance from main to curb stop 25.0'

Distance curb stop to meter N/A

Distance curb face to curb stop 2.0'

Depth of service 4.0'

Total length of new pipe installed 25.0'

Curb stop replaced: YES Size 1"

Corporation replaced: YES Size 1"

Ball Valve furnished NO: Size N/A

Remarks: 25.0' Corp to curb stop

# METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

# CHARGE OUTS

