

DUPLICATE

APPLICATION No.: 17627 - 4th

TAP CLEARED

LOCATION: 858-64 Purchase St.

OWNER: Grants

MEASURES: 4"

FIRE SUPPLY

March 4, 1976 Measure of 8 x 8 x 6 Tee, Mech.

N x N line Dover St. 28.6 ft.

E X W line Acush. Ave. 14.0 ft.

Tie in of 4" Fire Supply -

2.4 ft. - 6" C.I.C.L. Ductile Pipe SS

8 1/2 x 4 Reducer, class 250 Tyler, Mech.

N x N line Dover St. 28.6 ft.

E x W line Acushnet Ave. 10.6 ft.

1.2 ft. - 4" C.I.CL Ductile Pipe SS

4" Smith Blair #441 Cplg.

N x N line Dover St. 28.6 ft.

E x W line Acushnet Ave. 9.0 ft.

Due to the installation of the new 8" water main on Acushnet Ave. this service was tied into in the above order.

— — —

[illegible]

CHARGE OUTS

[illegible]

858 PURCHASE ST APPLICATION No.: 17627



TAP CLEARED

LOCATION: Acushnet Ave. W.S., S. of Elm

OWNER:

MEASURES:

4"

S from Elm 117.8 ft.

F S E from W line Acush.Av. 55 ft.

I U S from N line bldg 12.0 ft.

R P

E P

Chapman gate I.box

March 4^Y, 1976 Renewed from main to property line.

Installed by Fontani Const. in the following order:

1 - 8" x 8" x 6" Tee, Mech.

2.4 ft. - 6" Ductile Pipe

6 x 4 Reducer, class 250, Mech. Tyler

1.2 ft. - 4" Ductile Pipe

1 - 4" Smith Blair #441 Sleeve

- - -

Measures of 6 x 4 Reducer:

E x W line Acushnet Ave. 10.6 ft.

N x N line Dover St. 28.6 ft.

Measure of 4" Smith Blair #441 Sleeve:

N x N line Dover St. 28.6 ft.

E x W line Acushnet Ave. 9.0 ft.

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]