

TAP CLEARED 89-14-4867

LOCATION: 66-69 Duncan S.S., E. Of Acushnet Ave.

OWNER: Marcel J. Goyette

MEASURES:

5/8"

H Lead

E from

Acushnet Ave.

97.0

N from Sline

Duncan

8.4

E from W line

House

9.6

July 31, 1972 Renewed from 6" outside curb stop to property line
4 ft. 3/4" Copper tubing 1 wipe joint

— 222 —

Aug. 21, 1957 Renewed from property line to cellar
9 ft. of 3/4" copper tubing

.....

4/7/89: Renewed from lft. outside curb stop to a point 8 ft.
Stock: 8ft. 3/4" copper tubing 1-3/4" curb stop

Stock: 8ft. 3/4" copper tubing 1-3/4" curb stop
1 - Caldwell stop box 2-3/4 x 5/8 lead to cop adapt. xxs.

NOTE: DUG 2FT. INTO PROP STILL HAS LEAD IN OTHER WORDS
RENEWED FROM 6" OUTSIDE CURB STOP TO 2FT. INSIDE PROP

LEAD TO COPPER INSIDE OF PROP.

+++++FRONT+++++

METER HISTORY

[illegible]

CHARGE OUTS'

APPLICATION No.: 17644

TAP CLEARED

LOCATION: ~~66 Duncan street~~

OWNER:

31-313

MEASURES: 3/4 lead

DATE	BEF.	AFT.	REMARKS
------	------	------	---------

E X E LINE ACUSHNET AVE

97 ft

N X S LINE DUNCAN STREET

8.4 ft

E X W LINE HOUSE

9.6ft

W X E LINE HOUSE

17.5ft

N X N LINE HOUSE

16 ft

MAIN TO PROPERTY LINE

18ft

PIPE TO INSIDE PROPERTY

10ft

8/21/1957 renewed from property line to cellar 9ft 3/4copper

7/31/1972 renewed from 6" outside c/s to prop line 4ft

4/7/1989 renewed from 1ftoutside c/s to a poiny 8ft 3/4 copper

tubing 5/8 lead to copper adapt xxs *Note dug 2 ft into
property still has lead1/27/2022 JLC renewed from curbstop to meter
Percy inspected

METER HISTORY

[illegible]

CHARGE OUTS *

APPLICATION No.: 17644

LOCATION: 66-68 Duncan St

TAP CLEARED

OWNER: _____

31-313

MEASURES:

66-68 Duncan St

Date: 7/14/2023

Contractor: City of New Bedford

Renewed Main to CS

Type of Pipe: Copper

Size: ¾"

¾" ¾" Copper Tubing Type-K Copper Tubing-K Units 10 UOM Feet

CS Valve- ¾" Curb Stop Valve (3-4)" Units 1 UOM Each

CI-CRB-B Cast Iron Curb Stop Boxes Units 1 UOM Each

DATE

BEF.

AFT.

REMARKS

METER HISTORY

[illegible]

CHARGE OUTS