APPLICATION No.: 17757		TAP CLEARED			
CATION: 29-31 Branscomb St	DATE	BEF.	AFT.	REMARKS	
OWNER:					
ASURES: W from Acushnet Ave 278.2'					
S from N Line Branscomb St 8.1'					
E from W line House 11.7'					
1"COPPER SERVICE					
12/10/19: Lead service line replacement progr	an phase	1_			
TYPE:CU, Diameter 1", Water Pressure 95 Contractor: P. Gioioso & Sons					
Distance from main to curb stop 21.4'					
Distance curb stop to meter 24' Distance from curb face to curb stop 1.4'					
Depth of service 5.0'					
Total length of new pipe installed 21.4'					
Curb stop replaced: YES Size 1" Corporation replaced: YES Size 1"					
Ball VaLve furnished NO: Size 3/4"					
Remarks- 1-3/4" union installed where shown					

