

APPLICATION No.: 17778

LOCATION: 1015 Joyce N.W. Cor. Ahley Blvd.

OWNER: D. Blais

MEASURES: $5/8''$

W from

Ashley Blvd.

28.5 ft.

S from N line

Joyce

8.7 ft.

E from W line

house

2.4 ft.

Oct. 30, 1962 Renewed from main to a point 10 ft. from main.

10 ft. - 3/4" Copper tubing 5/8" reused corp. cplg.
1# wiping solder

Nov. 14, 1962 Renewed from a point 15 ft. from property line to a point 23 ft. from property line.

8 ft. - 3/4" Copper tubing 1 lb. wiping solder

✓ Aug 22, 1995: Renewed from main to prop line
Stock: 29ft 3/4" copper tubing 1-3/4" curb stop
1-3/4x5/8 lead-cop adapt. xs 1-3/4x5/8 Fig 413

August 5, 1996 Very low water pressure 998-9157
Checked 8/6/96 inside problem - told to call plumber

9-25-2000: Leak inside property line, 18' punch per Olejarz
Dry inside; no damage

✓ 3/21/01 Nelson Cardoso renewed service from property line to meter.

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

10/30/62

Reamed

8/22

953402021

8/22/95:	tap reamed
----------	------------

OK ELEC.

[illegible]