

17803

APPLICATION No.:

LOCATION: 1064 Dewey St (SS) E x Ashley Blvd

OWNER:

31-313

MEASURES: 5/8" Lead 10-28-1920

TAP CLEARED

DATE

BEF.

AFT.

REMARKS

7/10/12 - New measures:

E from E line Ashley Blvd	166.8
N from S line Dewey St	7.8
W from E line House	18.0
E from W line House	6.7
N from N line House	11.5
Main to Property Line	18.0
Pipe inside Property	8.0

[illegible]

## CHARGE OUTS





APPLICATION No.: 17803

TAP CLEARED 84-38-2795

LOCATION: 1064 Dewey S.S., E. of Ashley Blvd.

OWNER: Antoine Kicak

MEASURES:

5/8"

Lead

10/28/1920

E from	Ashley Blvd	166.8
N from S line	Dewey	7.8
E from W line	House	6.7

Nov. 14, 1980: Renewed from 6" outside curbstop to prop. line.

5.5 ft.-3/4" copper

1-3/4" curb stop 1-Caldwell stop box

2-5/8" x 3/4" lead-cop. adapt. XS

\*\*\*\*\*

Sept. 21, 1984 Renewed from main to a point 2.0 ft.

Stock: 2ft 3/4" copper tubing 1 5/8 x 3/4 lead to  
cop adapt. XS 1 5/8 x 3/4 Fig. 413

7/10/12 - RJ Canessa renewed this service from the  
curb stop to the meter. Owner charged \$140 (\$70  
inspection, \$45 turn-on, \$25 for 3/4" meter blank &  
couplings). Inspected by Percy. See new measures

DATE

BEF.

AFT.

REMARKS

9/21/84 tap reamed



[illegible]

## CHARGE OUTS

[illegible]