

APPLICATION No.: 17804

TAP CLEARED

LOCATION: 1052 Dewey S.S., E. of Ashly Blvd.

OWNER: Frank Bizaro

MEASURES:

3/4" from curb to cellar

E from Ashley Blvd. 282.8

N from S line Dewey 8.5

E from W line House 4.2

Change over to 3/4" 7-3-68

July 3, 1968 Renewed from 1/2 ft. outside curb stop to inside cellar

22 ft. - 3/4" copper tubing used.

10 ft. - 3/4" copper tubing from 1/2 ft. outside curb stop to property line.

12 ft. - 3/4" copper tubing from property line to inside cellar

3/4" curb stop. Mueller 1 wipe joint

10/20/03 Forestry Dept. removed tree. Excavated @ sidewalk; gutter line areas. Replaced 8' of 6" sewer line, 4" drain broken & not in use. Did not repair.

DATE

BEF.

AFT.

REMARKS



[illegible]

CHARGE OUTS

[illegible]