

APPLICATION No.: 17817

7-9 Fielding W.S., N. of Park Drive

LOCATION:

OWNER: A. Izcleski

MEASURES:

5/8" 3/4" COPPER
BROOKLAWN ST

N from	Park Drive	82.4
E from W line	Fielding	8.5
S from Nline	House	8.9

11/09/1920

9/11/90: TAP REAMED

8/12/10 8:00

8/19/10

2010-3209861

Tap reamed

9/11/90: Renewed from 1 ft. outside curb stop to a point
 1 ft inside Stock: 2ft. 3/4" copper tubing
 1 - 3/4" curb stop 1-Caldwell stop box
 2 - 3/4x5/8 lead to cop adapt. xxs
 =====

8/19/10 - City crew renewed service from main to meter
 in cellar (16 ft inside property line)

32 ft - 3/4" copper tubing; 1 - 3/4" curb stop;
 1 Caldwell stop box; 1 - 5/8" x 3/4" Fig. 413;
 Tap reamed. Foreman: Danny Perry

TAP CLEARED

90370116

DATE

BEF.

AFT.

REMARKS

METER HISTORY

[illegible]

CHARGE OUTS