

APPLICATION No.: 17838

TAP CLEARED ✓

LOCATION: 994 Ridge St.

OWNER: Antone Medeiros

MEASURES:

5/8"

Copper  
~~Lead~~

Nov. 24, 1920

S from

Winterville Rd. 76.3 ft.

W from E line

Ridge St. 8.0 ft.

N from S line house

5.5 ft.

Aug. 11, 1977: Renewed from 6" outside curbstop to inside cellar wall. 16 ft. - 3/4" copper (8 ft. ins.); 3/4" curb stop; Caldwell stop box; 5/8" x 3/4" lead to cop. adapt. XS

8/15/85: Renewed from main to a point 1.5 ft.

Stock: 1.5 ft. 3/4" copper tubing 1 3/4x5/8 lead to cop adap.xs

1 3/4x5/8 Fig. 413

=====

12/16/10 - City crew renewed water service from main to curb stop

24 ft - 3/4" copper tubing; 1 - 3/4" curb stop;

1 Caldwell stop box; 1 - 5/8" x 3/4" Fig 413; tap cleaned

Foreman: Danny Perry

[illegible]