

APPLICATION No.: 17846

TAP CLEARED



LOCATION: 117 WINTERVILLE RD

OWNER: ANTONE ANDRADE

MEASURES: 3/4" COPPER

DEC 28, 2015

W FROM ROCKDALE AVE  
S FROM N WINTERVILLE RD  
W FROM W HOUSE

1020.0ft  
7.4ft  
1.0 ft

Street reconstruction Aug 14, 1997

Renewed from main to curb stop

Stock: 23ft 3/4" copper tubing 1-3/4" curb stop

1-caldwell stop box 1-3/4x5/8 Fig 413

=====

12/28/15: contractor renewed from curb stop to meter  
inside cellar with 3/4" copper pipe. contractor: wc smith  
inspected by: p.r.

DATE

BEF.

AFT.

REMARKS

8/14/97: tap reamed



(117) ON HOUSE

APPLICATION No.: 17846

TAP CLEARED P322-0892

LOCATION: ~~130~~ Winterville Rd. N.S., W. of Rockdale Av.

OWNER: Antone Andrade

MEASURES: 5/8" L lead

W from Rockdale Av. 1020.0 ft.  
S from N Witherville Rd. 7.4 ft.  
W from W house 1.0 ft.

Change over to 3/4"

-----  
July 7, 1965 Renewed from 1/2 ft. outside curb stop to meter inside the building.

14 1/2 ft. of 3/4" copper tubing 1 3/4" curb stop  
1 wipe joint 1# wiping solder

-----  
JUN 2 1983 -- Renewed from main to a point 6 ft. from main.  
6.0 ft. - 3/4" copper; 5/8" x 3/4" Fig. 413; 5/8" x 3/4"  
lead-cop. adapt. XXS;

-----  
*Mayor's office called water in back of house  
Drainage Problem J Ryzardo 3/6/91*

7-6-92 SINK HOLE ST. W/ BARREL ? DPW

DATE BEF. AFT. REMARKS

JUN 2 1983 Reamed

8/14/97 973 305579



[illegible]

## CHARGE OUTS

[illegible]