APPLICATION No.: _____ 17849

LOCATION: ___ 92 Winterville Rd. S.S., W. of Rockdale Av.

OWNER: ___ Augusto Teixeira

MEASURES: 5/8"

	W from	Rockdale Ave.	728.0 ft.
	N from S	Winterville Rd.	9.0 ft.
	W from E	house	7.4 ft.

2/22/78: Renewed 6" outside curb stop to 4 ft.-inside.
4½ ft.-3/4" copper; 3/4" curb stop; 2-3/4" x 3/4" lead to
cop. adapt. XXS; Caldwell stop box;

Doucet,

April 24,1996:Renewed from main to ins.cellar (4ft ins.cellar)
Stock: 23ft 3/4" copper tubing 1-3/4" curb stop
1-Caldwell stop box 1-3/4x5/8 Fig 413
                        ======

TAP CLEARED			✓
DATE	BEF.	AFT.	REMARKS
8/4/77		4/24/96	9617-04116
			Clean Elect
4/24/96:	tap reamed		
8/6/97			973203875

METER HISTORY

CHARGE OUTS

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS
11/9/64		5/8	Hersey	522652					