

44 APPLICATION No.: 17891

LOCATION: Wamsutta S.S., W. of Front

OWNER: NORTHERN D.G. ELECTRIC

MEASURES: 4" 4" 4" FIRE SUPPLY NOTE: SEE BACK OF CARD

Chapman I box

W from	Front	373.3 ft.
S from N	Wamsutta	45.0 ft.
W from E	Addition	4.3 ft.
E from E	Old Bldg.	5.7 ft.

August 27, 28, 1973 Renewed 4" cast iron fire supply from an existing 6" x 4" reducer into the property line. The 6" x 4" reducer was located at a point 34 ft. N x S line of Wamsutta St. The old 4" gate valve was abandoned in place along with 20 ft. - 4" pipe (from S.L. Wamsutta St. to a point 20 ft. N x S line Wamsutta St.)
 Stock: 37.6 ft. - 4" Cast Iron c.L. Pipe tyton
 1 - 4" Mineralead joint 1 - 4" Asb. Yarn Joint

Measures of 6" gate valve:

W x W line of No. front St.	373.0 ft.
N x S line Wamsutta St.	38.0 ft.
W x E line Bldg.	3.5 ft.
N x N line Bldg.	38.0 ft.
(Bldg. on property line)	

Dec. 30, 1992 Repaired a split in 4" pipe at a point 16.5 ft. N x S line Wamsutta St. Removed old 4" pipe that had been abandoned & removed old 4" gate valve. Also removed tap for old ser. #17892 & stop box for service which had been tapped on 4" F.S. Gate Box for 4" gate also removed. Left a pc. of 4" from old 4" gate to ins. bldg. left abandoned in place.
 1 - 4" Smith Blair #226 single band clamp 7 1/2" w.

TAP CLEARED

DATE BEF. AFT. REMARKS

12/30/92

93 01-1702

[illegible]

— 6" GATE
 — 6" PIPE
 — 6" x 4" REDUCER
 — 4" PIPE - 2 FT LONG
 — 4" PIPE - 20 FT. LONG
 — 4" PIPE - 15.6 FT. LONG

EXISTING PIPE
 NEW PIPE

8/27-28/73