

17902

APPLICATION No.:

TAP CLEARED

LOCATION: 122 Maywood St E.S., N X Carlisle St.

DATE

BEF.

AFT.

REMARKS

OWNER:

31-313

MEASURES: 3/4" Copper

Original Date: 03-18-1921

8-18-08 - New Measures:

N from N line	Carlisle St	233.0
W from E line	Maywood St	6.5
N from S line	House	6.0
S from N line	House	21.0
W from W line	House	16.4
Main to Property Line		31.0
Pipe inside Property		12.0

8-18-08 - Franklin Bro. renewed from curb stop into cellar  
Inspected by Percy Reynolds

[illegible]



APPLICATION No.: 17902

TAP CLEARED ✓

LOCATION: 122 Maywood E.S., N. of Carlisle

OWNER: Henry Bariteau

MEASURES: 3/4"

N from	Carlisle	235.3 ft.
W from E line	Maywood	8.0 ft.
N from S line	House	5.8 ft.

Sept. 8, 1975 Renewed from the main to a point 3 ft. from  
the main.

3 ft. - 3/4" Copper tubing 3/4" Fig. 413 x 1"  
5/8" lead to copper adaptor XXS

- - -

Dec. 8, 1976 Renewed from 1/2 ft. outside curb stop to  
the prop. line.

10 ft. - 3/4" Copper tubing 3/4" Curb Stop  
Caldwell Stop Box 2 - 3/4" x 3/4" lead conn.

- - -

4/13/93: Renewed from main to curb stop Stock: 26ft 3/4" copper  
tubing 1-3/4" curb stop 1-Caldwell stop box 1-3/4x5/8 Fig 413

=====

8/11/08 8:30<sup>AM</sup> Leak found btwn. prop. line to meter (Paul Monteiro) 8/15/08 Owner called  
Franklin Bros to do renewal, Owner states Franklin can Shut-off + Turn-on.

DATE

BEF.

AFT.

REMARKS

4-13-  
93

9316 1656

4/13/93: tap reamed

[illegible]

## CHARGE OUTS

[illegible]