

APPLICATION No.: 1793

TAP CLEARED 0058-1864

LOCATION: 297 County St.

OWNER: Alfred Berthiaume

DATE BEF. AFT. REMARKS

9/18/85: TAP REAMED

MEASURES: 5/8"

H lead

June 11, 1874

W from

County St.

29.6 ft.

S from N line

Sherman St.

61.8 ft.

W from E line

house

10.6 ft.

✓ 9/18/85: Renewed from main to property line

Stock:

1 - 5/8" x 3/4" lead to copper adapt XXS

24 ft. 3/4" copper tubing 1-3/4 curb stop 1-Caldwell stop
box =====

✓ 7/7/89: Renewed from newly installed 6" ductile main to a point

1 ft. Brito Const. supplied & installed stock:

1 ft. - 3/4" copper tubing 1-3/4" corp tap

1 - 3/4 x 3/4 cop to cop cplg. comp. Brito Const to maintain
trench. Insp M. Rose. =====

12/16/95 Shut off - Vacant - Smalley

Meter room cant get in for meter

1/9/97 Checked by Olejarz - OFF

✗ MUST CHANGE LEAD TO COPPER BEFORE TURNING ON

✓ May 29, 1997: OWNER renewed serv. from 3ft S x N line SHerman
St. to meter Stock: 1-3/4x3/4 cop-cop cplg.comp at a point
S x N line Sherman ST. 3 ft

[illegible]

CHARGE OUTS

[illegible]