	APPLICATION No.:	TAP CLEARED			
LOCATION:_	25-27 Branscomb St	DATE	BEF.	AFT.	REMARKS
OWNER:	\				
MEASURES:	W from Acushnet Ave 236.0' S from N line Branscomb St 8.0' E from W line house 10.6' 1"COPPER SERVICE 12/10/2019: Lead service line replacement prophase 1: TYPE CU, Diameter 1", Water Pressure Contractor: P. Gioioso & Sons Distance from mai to curb stop 20.6' Distance curb stop to meter 23.3' Distance from curb face to curb stop 1.5' Depth of service 4.0' Total length of new pipe installed 43.9' Curb stop replaced: YES Size 1" Corporation replaced:YES Size 1" Ball Valve furnished:YES Size 1" Remarks- Installed service Saddle with 1" Corporation of the service of the se	95	show	n	

