	80 Forest St APPLICATION No.: 18012	TAP CLEARED			
LOCATION:_		DATE	BEF.	AFT.	REMARKS
OWNER: _					
MEASURES:					
	July 14,1921				
	E from Bonney St 97.5'				
	N from S line Forest St 6.6' E from E line house 10.6'				
	1"COPPER SERVICE				
	9-6-2018: Lead service line replacement progra	m			
	phase 1, Contractor, P. Gioioso & Sons TYPE CU, Diameter 1', Water Pressure 80				
	Distance from main to curb stop 8.5'				
	Distance curb stop to meter 17				
	Distance from curb face to curb stop 1.6' Depth of service 4'				
	Total length of new pipe installed 8.5'				
	Curb stop replaced: YES Size 1"				
	Corporation replaced: YES Size 1" Ball Valve furnished: NO Size N/A				
	ball valve latitudiea ino bibe in, ii	_			
*					
			*		

