

APPLICATION No.: 18053

LOCATION: 224 Mt. Pleasant E.S., S. of Adams

OWNER: J.P. Gomes

MEASURES: $3/4"$

S from

Adams

60.3 ft.

W from E line

Mt. Pleasant

2.0

~~6-7 ft.~~

S from N line

House

7.0 ft.

Dec. 23, 1959 Renewed from main to curb stop

11 ft. - 3/4" Copper tubing

NOTE: The 3/4" cop to cop cplg. was relocated from near the curb stop to near the corporation.

Nov. 24, 1959 Renewed from 1 ft. outside curb stop to $\frac{1}{2}$ ft. inside curb stop.

1 1/2 ft. - 3/4" Coppertubing

3/4" cop to cop stop

2# wiping solder

AUG 19 1981 - Renewed service from the 8" main to the property line. 6.0 ft. - 3/4" copper; 3/4" curb stop; stop box; 1-5/8" x 3/4" lead-cop. adapt. XXS

Note: No saddle on transite pipe.

Change meter 3/15/90 complain of poor pressure only 28 lbs. in street.

3/24/92: Renewed from main to a point 2ft. Stock: 2ft 3/4"
copper tubing 1-3/4x3/4 cop-cop cplg.comp 1-3/4x3/4 Fig 413

NOTE: MAIN WAS ON THE 17FT. LINE

+++++LINE+++++

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

AUG 19 1981

3/24/92	
---------	--

Reamed -

9213 1016

3/24/92: TAP REAMED

[illegible]

CHARGE OUTS

[illegible]