

127-129

APPLICATION No.: 18057

TAP CLEARED

LOCATION: ~~225~~ Union N.S, W. of So. Second

DATE

BEF.

AFT.

REMARKS

OWNER: ~~Alum~~ Herman

MEASURES: 4"

FIRE SUPPLY

Darling gate, I box

W from So. Second 86.6 ft.

N from S line Union 18.8 ft.

W from E line Bldg. 4.1 ft.

 May 9, 1969 This service now tied into new 12" main on Union St.
 So. Terminal Work

 April 27, 1969 Installed a temporary service.

1 8" x 1 1/2" dresser service saddle 1 1 1/2" Hays tap

1 1 1/2" Mueller curb stop 40 ft. of 1 1/2" copper tubing

D-4 drilling machine

 July 15, 1959 Repaired leak in 4" Fire Supply.

1 4" Dresser Style 360

 Service removed.. The Gioioso installed new service
 34050 per Cliff

[illegible]