

880

APPLICATION No.: 18120

TAP CLEARED

LOCATION:

~~880~~ Purchase St. N.E. cor. Elm

OWNER:

Olympia Theater Inc. *Building*

MEASURES: 3"

C.I.

Darling Gate, I. Box

E	Purchase St.	55.0 ft.	54.0
NS from NS	Elm St.	6.2 ft.	21.2
E from EW	Bldg.	47.0 ft.	54.0
S from N	Bldg.		17.0

April 24, 1974 This service broken by Frdrico Const.

2 ft. - C.I. Pipe 3" 1 - 3" Solid Sleeve C.I.

3 - 3" leadite joints 3 asbestos gasket

The sleeve is located 9.7 ft. south of 3" gate which controls this service.

Jan 19, 1975 Renewed from the new 30" main in Elm St. to inside cellar.

30" x 30" x 6" C.I.C.L. tee, Mj 1 6" smith mech. gatevalve

14.2 ft. 6" C.I.C.L. class 2 ductile pipe 1 buffalo gate box

3.5 ft. of 3" C.I.C.L. pipe(not ducitle) 1 6" x 3" C.I.C.L. reducer

4.0 ft. 3" copper tubing 1 3" pipe strap with 3/4"

1 3" cop. to cop. elbow threaded rods (4 ft.)

1 3" cop. to i.p.s. male adaptor

1 3" copper caulking connection 1 3" lead jt. 1 3" asb.yarn.jt.

Measure of 6" x 3" reducer:

E x E line Purchase St. 54.0

S x N line Elm St. 5.0

[illegible]

CHARGE OUTS

[illegible]