

APPLICATION No.: 18142

TAP CLEARED 8916-3435

LOCATION: 70 Irvington S.S., E. of Concord

OWNER: Francisco Apolinario

MEASURES: 5/8"

E from

Concord

60.6 ft.

N from S line

Irvington

7.1 ft.

W from E line

house

13.1 ft.

Oct. 7, 1977: Renewed 6" outside of curb stop to 2 ft. inside curb stop. 2 1/2 ft. - 3/4" copper; 3/4" curb stop; 2-5/8" x 3.4" lead to copper adapt. XXS; Caldwell stop box

1-12-89

LEAKING AT GROUND CLAMP - WILL CALL PLUMBER

G. PITA

S.R.

9956854

Jan. 14, 1989 Repaired & changed over to 3/4" meter hook up with lead to copper adaptor at wall., 6" pc. - 3/4" copper - 1 new 3/4" shut off (bought by owner) and two new 3/4" tail pieces. Owner blamed meter change for broken lead at ground clamp called Gelinas Plumb., they would not touch it.

4/20/89: Renewed from 1 ft. outside curb stop to ins. cellar (16 ft. ins. prop line) 6 ft. from prop line to curb stop

Stock: 22 ft. 3/4" copper tubing 1-3/4" curb stop

1 - Caldwell stop box 1-3/4x5/8 lead to cop adapt. xs

[illegible]

CHARGE OUTS

[illegible]