

APPLICATION No.: 18201

TAP CLEARED

LOCATION: 265 - 267 Eugenia St

DATE _____

BEF.

AFT.

REMARKS

OWNER:

09/05/89 Reamed

31-313

MEASUREMENT X Brook St 62.4 ft

62.4 ft

S X N line Eugenia St 9.0 ft

9.0 ft

E X W line House 13.1 ft

13.1 ft

1" Copper Service

04/04/2018 Lead Service Line Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 60

Distance from main to curbsto (ft) 23.7

Distance from curb stop to meter (ft) 21.8

Distance from curb face to curb stop (ft) 2.0

Depth of service (ft) 4.3

Total length of new pipe installed (ft) 45.5

Curb stop replaced: yes, size 1"

Corporation replaced: yes, size 1"

Ball valve replaced: yes, size 1"

METER HISTORY

CHARGE OUTS

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST		REMARKS

