

APPLICATION No.: 18238

TAP CLEARED

LOCATION: 89 Sylvia N.S., E. of Belle Ave.

OWNER: M Lopes

MEASURES: 5/8"

E from	Belle Ave.	107.2 ft.
S from N line	Sylvia	8.6 ft.
E from W line	House	2.4 ft.

6/5/78: Renewed from 6" outside curb stop to inside cellar wall. 27 ft.-3/4" copper (18 ft. ins.); 3/4" curb stop; 5/8" x 3/4" lead to cop. adapt. XXS; Caldwell stop box;

April 4, 1997: Lead serv. replacement

Renewed from main to curb stop

Stock: 24 ft 3/4" copper tubing same curb stop  
same Caldwell stop box 1-3/4x5/8 Fig 413

[illegible]

1/18/07 Repaired service from 10 ft. outside curb stop to point  
13 ft. (using 3 ft. 3/4" copper; 3/4" curb stop; 3/4" x 3/4"  
cop-cop cplg.) Bento

NOTE: Gas Co. pulled service & will maintain street and sidewalk

— — — — —

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

4/4/97

971403544.

4/4/97: tap reamed

[illegible]

## CHARGE OUTS


[illegible]

\_\_\_\_\_ Renewed from main to a point      ft.  
 \_\_\_\_\_ Renewed from main to curb stop.  
 \_\_\_\_\_ Renewed from main to property line.  
 \_\_\_\_\_ Renewed from main to inside cellar. (      ft. ins. prop. line)

\_\_\_\_\_ Renewed from 1/2' outside curb stop to a point      ft.  
 \_\_\_\_\_ Renewed from 1/2' outside curb stop to prop. line.  
 \_\_\_\_\_ Renewed from 1/2' outside curb stop to ins. cellar. (      ft. ins. prop. line)

STOCK:

3 ft. - 3/4" Copper tubing  
 1 - 3/4" Curb Stop  
 1 - Caldwell Stop Box  
 - \_\_\_\_\_ lead to cop. adapt. \_\_\_\_\_  
 1 - 3/4 x 3/4 cop to cop cplg., comp.  
 - \_\_\_\_\_ Fig. 413  
 - \_\_\_\_\_ " Corporation tap  
 - \_\_\_\_\_ Service Saddle  
 - Tap Reamed



Repair service from 10' OUT-SIDE CURB STOP TO POINT  
 13' (USING 3'-3/4" COP 1-3/4" CURB STOP - 1-3/4 x 3/4 COP TO COP)

ST. CUT:

SIDE. CUT:

GASCOMP will maintain  
 STREET & SIDE WALK