APPLICATION No.: 18265		TAP	CLEAR	ED 8946 -005B
LOCATION: 417 Oliver W.S., N of Brockton	DATE	BEF.	AFT.	REMARKS
OWNER: S. Barbonneau				V
MEASURES: 3/4 N from Brockton E from W line Oliver N from N line House 11/13/89: Renewed from 1 f.t outside curb stop to a point 2 ft Stock: 3 ft. 3/4" copper tubing 1-3/4" curb stop 1 - Caldwell stop box 2-3/4 x 5/8 lead to cop adapt. xxs 10-6-2020: Inspection of renewal, curb stop was broken dug up to shut off. Contractor: Nathaniel Gomes Inspector P. Reynolds		/		
N x N line Brockton St 127.6' E x W line Oliver St 7.7' N x S line house 21.0' N x N line house 2.3' E x E line house 46.0' Main to prop line 18.0' Pipe inside property 50.0'				
DPI, Rui Martins / Lead service changed from main to curb stop, 1- cast iron curb sto curb stop valve, 10ft of copper tubing 3/4" 1- 5/8" corp adapter	p box, 1-3	3/4"		

METER HISTORY								CHARGE OUTS	
DATE	SET	SIZE	MAKE	NUMBER	READING		TEST	REMARKS	
8-31-	48	3/1	ı King	186664					
,									

	7								