

56

APPLICATION No.: 18413

TAP CLEARED

LOCATION: 367 North N.S. W of Hunter.

OWNER: Jos. S Hathaway

MEASURES: 3/4"

W from	Hunter	126.6 ft.
S from N line	North	7.2 ft.
E from W line	House	11.3 ft.

DATE

BEF.

AFT.

REMARKS

12/3/96

964901516.

10-20
94

9442-05403

clear Elec.

10/20/94: tap reamed

 July 25, 1973 Renewed from 6" outside curb stop to inside cellar.
 21 ft. of 3/4" copper tubing (13 ft. inside)
 1 3/4" Hays curb stop compression
 1 5/8" Ford XXS adaptor 1 Caldwell Stop Box

12/12/89 Inquiring about low pressure

4/19/91 Took cold sample clear 4/19/91

8-4-94 COMPLAINED POOR PRESSURE - METER ROOM TO CHECK 8.5
6.5 G.P.M.

10/20/94: Renewed from main to a point 1ft
 Stock: 1ft 3/4" copper tubing 1-3/4x5/8 lead-cop adapt.xxs
 1-3/4x3/4 Fig 413

=====

11-1-94 WENT TO CITY HALL - COMPLAINT STILL POOR PRESSURE
 WANTS AN COPPER.

12-09-94 OWNER COMPLAINT POOR PRESSURE
 WANTS LEAD SECU. CHANGED TO COPPER

12/2/96 - OWNER ASK ABOUT REAMING
 LEAD SERVICE - TOLD OWNER IT WOULD BE AT HIS COST.

[illegible]

CHARGE OUTS

[illegible]

APPLICATION No.: 18413

TAP CLEARED

LOCATION: 367 NORTH ST N .S. W X HUNTER

OWNER: JOS. S HATHAWAY

MEASURES: 3/4"

W FROM	HUNTER ST	126.6 ft
S FROM N LINE	NORTH ST	7.2 ft
E FROM W LINE	HOUSE	11.3 ft

Dec 3, 1996: Renewed from main to curb stop
Stock: 23.0ft 3/4" copper tubing same curb stop
same Fig 413
=====

DATE

BEF.

AFT.

REMARKS

12/3/96: tap reamed

[illegible]

CHARGE OUTS

[illegible]