

APPLICATION No.: 18536

# TAP CLEARED

LOCATION: 430-2 Sawyer S.S. E. of Reynolds

OWNER: Alphonse Azevedo

11-10-65

Reamed

MEASURES:	5/8"	L lead	5-25-22
	E from	Reynolds	129.0 ft.
	N from S line	Sawyer	8.8 ft.
	W from E line	House	11.8 ft.

7/29 8830-4529

7-24-2000	Tap reamed
-----------	------------

June 14, 1973 Renewed from the main to a point 4 ft.  
from the main.  
4 ft. - 3/4" Copper tubing 3/4" Copper cplg.  
1" x 3/4" Fig. 413

This service broken by C. Franklin

November 10, 1965 Renewed service from main to 4 ft. inside curb stop.

13 ft. of 3/4" copper tubing	1 3/4" cop. to cop. stop
1 lb. wiping solder	1 5/8" reused corporation coupling

7/29/88: Renewed from curb stop to ins cellar.(10 ft. ins prop line) Stock: 20 ft. 3/4" copper tubing 1-Caldwell stop box

+++++

7-24-2000 Renewed from main to property line. Stock:  
18 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop, 1 - Caldwell  
Stop Box, 1 - 5/8" x 3/4" lead to cop. adapt. XS,  
1 - 5/8" x 3/4" Fig. 413, Tilcon to maintain cut.

NOTE: TURN OVER FOR MORE INFO ON REPAIRS \*\*\*\*

[illegible]

## CHARGE OUTS

[illegible]