

APPLICATION No.: 18551 5/8"

TAP CLEARED ✓

LOCATION: 506 Brock Ave.

OWNER: Y.K. Fontaine

MEASURES: 5/8"

01-01-1923

N from

Annette

138.4 ft.

W from E line

Brock Ave.

11.0 ft.

2/24/92: Renewed from 1/2' outside curb stop to a point 2ft

Stock: 3ft 3/4" copper tubing 1-3/4" curb stop

1-Caldwell stop box 2-3/4x5/8 lead-cop adapt.xxs

8/13/09 - City crew renewed portions of water service - from main to a point 4 ft & from 5 ft outside curb stop to a point 17 ft outside curb stop

16 ft - 3/4" copper tubing; 3 - 5/8" x 3/4" lead to cop adapt xxs; 1 - 5/8" x 3/4" Fig 413; Tap reamed. Foreman: Frank Bento

Notes: There is electric ducts on outside of water mains, 2 gas mains & 2 sets of trolley tracks in the way of changing this entire service over to copper, only was able to patch service line.

-----

DATE

BEF.

AFT.

REMARKS

2-24-92

9209 0045

8-13-09

1:00

2009-3305637

8-13-09

Tap reamed

## METER HISTORY

[illegible]

## CHARGE OUTS