	APPLICATION No.: 18577		TAP CLEARED			
LOCATION:_	57-9 Capitol		DATE	BEF.	AFT.	REMARKS
	Robert Caron				12-14-	92510027
MEASURES:			4-13-07		9:45	2007-150-3268
71.27.001.201	5/10"	H lead May 20,1922	4/7/07			Tap reamed
	E from	W.French Ave. 600.3 ft.				
	S from N line	Capitol St. 8.8 ft.				
	E from W line	house 3.8 ft.				
10/1/80 :shut off handle broken owner notified to get plumber Owner-John Paiva						*
12/14/92: Renewed from ½' outside curb stop to a point 5ft Stock: 5ft 3/4" copper tubing 1-3/4" curb stop 1-Caldwell stop box 2-3/4x5/8 lead-cop adapt.xxs NOTE: CURB STOP						
WAS BROKEN BY SCHLUMBERGER CO WHILE CHANGING METERS.						
4/7/07 Renewed from main to property line. Stock: 22 ft. 3/4"						
copper tubing; 3/4" curb stop; 5/8" x 3/4" Fig. 413 Tap reamed						**
Monty						
			2.			
BRADBURY-WARING, INC.						

