

APPLICATION No.: 18652

TAP CLEARED

LOCATION: 157-9 Carroll St.

OWNER: Mary A. Santos

MEASURES: 5/8" L lead May 25, 1922

E from Reed St. 90.6 ft.

S from N line Carroll St. 9.9 ft.

W from E line body of house 3.0 ft.

Sept. 19, 1977 Renewed from 6" outside curb stop to inside cellar.

21 ft. - 3/4" Copper tubing (11 ft. inside)

3/4" curb Stop Caldwell Stop Box

5/8" x 3/4" lead to copper adaptor XXS

- - -

9/26/2018 emergency curb stop leak repair

3/4 copper tubing 3/4 curb stop valve, cast iron stop boxes, 5/8 corp adapter
Daniel Perry

Ronnie Aguiar

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS