

APPLICATION No.: 18700

TAP CLEARED

LOCATION: 199 - 201 Hersom St

DATE

BEF.

AFT.

REMARKS

OWNER:

10/17/2000

31-313

MEASURES:

W X Fielding St

80.9 ft

S X N Line Hersom St

9.0 ft

1" Copper Service

04/25/2019 Lead Service Line Replacement

Program, Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 85

Distance from main to curb stop (ft) 23

Distance curb stop to meter (ft) 23.3

Distance from curb face to curb stop (ft) 4.3

Depth of service (ft) 4.4

Total length of new pipe installed (ft) 23.3

Curb stop replaced: no size 3/4"

Corporation replaced: no size 3/4"

Ball valve furnished: yes size 1"

Remarks: 1-3/4" union installed 1 ft outside
curb stop

[illegible]

This image shows a blank, aged, cream-colored page, likely an endpaper or flyleaf of a book. The paper has a slightly textured appearance with some faint smudges and discoloration, characteristic of old paper. A small, dark rectangular mark is visible near the bottom center of the page.

