

APPLICATION No.: 18710

TAP CLEARED 8809-0044

LOCATION: 314 Hemlock St.

OWNER: Manuel Dias Et Ux

MEASURES: 5/8" H lead June 2, 1922

N from Osborn St. 29.9 ft.

W from E line Hemlock St. 7.2 ft.

S from N line house 2.3 ft.

2-29-88 Renewed from main to a point 1 ft  
1ft-3/4" copper tubing, 1-3/4" curb stop, 1-Caldwell stop box  
1-5/8x3/4 lead to cop adapt xxs1-5/8x3/4 Fig 413

8/5/10 - City crew renewed water service from main to

~~curb stop~~ Property Line

31 ft - 3/4" copper tubing; 1 -3/4" curb stop; 1 Caldwell  
stop box; 1 -5/8" x 3/4" lead to cop adapt xs;

Tap reamed. Foreman: D. Perry

2-21-17 renewed c/s to meter long side

16 ft 3/4" copper tubing

1 ft 3/4" ball valve

1 ft 3/4" x 1/2" brass bushing

1 ft 3/4" 90\* threaded copper

lead worker: manny washburn dpi

DATE

BEF.

AFT.

REMARKS

2-29-88

reamed

8/5/10 8:00

2010-3207360

8/5/10

tap reamed

[illegible]

## CHARGE OUTS

[illegible]