

(478 on house)

APPLICATION No.: 18734

TAP CLEARED

LOCATION: 476 Brock Ave.

OWNER: John Nemeth

MEASURES: 5/8" H lead June 8, 1922

S from Annette St. 58.3 ft.

W from E line Brock Ave. 10.3 ft.

S from N line house 13.0 ft.

April 13, 1977 Renewed from  $\frac{1}{2}$  ft. outside curb stop  
to inside cellar.

18 ft. -  $\frac{3}{4}$ " Copper tubing (7 ft. inside) $\frac{3}{4}$ " Curb Stop Caldwell Stop Box1 -  $\frac{5}{8}$ " x  $\frac{3}{4}$ " lead connector

- - -

July 21, 1981 Removed service from old 8" main and  
retapped into 16" main. Killed  $\frac{5}{8}$ " service at tap of  
old 8" main. Tapped 16" main.

2 $\frac{1}{2}$  ft. -  $\frac{3}{4}$ " Copper tubing  $\frac{3}{4}$ " Corporation $\frac{5}{8}$ " x  $\frac{3}{4}$ " lead to copper adapt XS

- - -

Tap is 2 ft. north x center of gate

18' N x S line Lucas St.

24' E x W line Brock Ave.

During Brock Ave. Tie-in Project.

DATE

BEF.

AFT.

REMARKS

## METER HISTORY

## CHARGE OUTS

[illegible]