

APPLICATION No.:

18795

LOCATION:

173 CLIFFORD ST.

OWNER:

Rosalina LaPorte

31-313

Measures: 5/8"

E from Ashley Blvd 74.5'

N from S line	Clifford	8.6'
---------------	----------	------

W from E line    House    8.9'

### 1" Copper Service

09/14/2022 2022 Water main improvement program

Contractor: C. Naughton Corp.

Type CU Diameter 1"

Distance from main to curb 22.50'

Distance from curb stop to meter 20'

Distance curb face to curb stop 1.50

Depth of Service 4.50'

Total length of new pipe installed 42.50'

Curb Stop replaced yes size 1"

Corporation replaced yes 1"

Ball Valve replaced yes N/A

Remarks: Type C- 1" Copper to meter

TAP CLEARED

DATE \_\_\_\_\_

BEF.


AFT.

REMARKS

# METER HISTORY

## CHARGE OUTS

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS



CLIFFORD ST.