

APPLICATION No.: 18816TAP CLEARED G 2674LOCATION: 319-321 N. E. Cor. Hawthorn and ReedOWNER: Edwin JonesMEASURES: 5/8"

N from Hawthorn	59.3 ft.
W from E line Reed	8.7 ft.
S from N line house	8.8 ft.

Feb. 2, 1976 Renewed from 6" outside curb stop to inside cellar wall.

14 ft. - 3/4" Copper tubing (5 ft. inside)

3/4" Curb Stop Caldwell Stop Box

3/4" x 5/8" lead to copper adaptor XXS

8/3/77 Renewed from main to 8.6 ft. from of main. 8 1/2 ft. - 3/4" cop;
3/4" x 3/4" Fig. 413; 5/8" x 3/4" lead to cop. adapt. XXS

RENEWED FROM MAIN TO A POINT

7/14/81: ~~Renewed~~ 15 ft. East of main. 15 ft. - 3/4" copper;
3/4" curb stop; Same Fig. 413; 1-5/8" x 3/4" lead-cop.
adapt. XS; A 3/4" Curb stop was installed at a point 15'
E x main or 12' west of curb stop buried.

10-25-2000 Silva Const. renewed from main to curb stop. Stock:
25.6 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop, 1 - Caldwell
Stop Box, 1 - 3/4" Corporation tap. Silva Const. to maintain cut.

DATE

BEF.

AFT.

REMARKS

8/3/77

Tap reamed

7 /14/81

"

[illegible]

CHARGE OUTS

[illegible]