

18858

OWNER: JOSEPH G CORREIA

31-313

E FROM	CLEVELAND ST	448.4 ft
N FROM S LINE	FREDERICK	8.2
E FROM W LINE	HOUSE	7.0

Renewed from curb stop to inside cellar

Property line to inside cellar 17 ft Stock: 23 ft 3/4" copper
tubing same curb stop 1-Caldwell stop box

[illegible]

18858

APPLICATION No.:

TAP CLEARED 8426-2404

LOCATION: 84 Frederick S.S., E. of Cleveland

OWNER: Joseph G. Correia

MEASURES:

5/8" Ser. increased to 3/4 from Curb
 3/4 Meter Stop into Balg. 9-15-64 34
 286

E from	Cleveland	448.4
N from S line	Frederick	8.2
E from W line	House	7.0

Sept. 15, 1964 Renewed service from $\frac{1}{2}$ ft. outside curb stop to
 meter inside cellar 24 ft. 3/4" copper tubing
 3/4" cop. to cop. stop, fig. 415 lb. wiping solder

July 3, 1984 - Renewed from main to curb stop.
 9.9 Ft. - 3/4" copper tubing; 1 - 3/4" curb stop;
 1 stop box; 1 - 5/8" x 3/4" Fig. 413.

4/24/86: Renewed from inside curb stop to 2.0ft. inside prop.
 Stock: 9.0ft. 3/4" copper tubing 1 - 3/4x3/4 cop to cop cplg.
 comp.. NOTE: 3/4" COPPER INSIDE OF PROPERTY IS VERY POURIOUS
 AND HAS PINHOLES IN IT. THERE ALSO IS AN ACCUMULATION OF RUST
 OR WHATEVER INSIDE THE COPPER.

12-9-93 DUARTE STATES THERE IS AN INSIDE LEAK

DATE

BEF.

AFT.

REMARKS

7/3/84

REAMED

8617-1747

3/29/95

9513-03344

Clear Elect.

[illegible]

CHARGE OUTS