

APPLICATION No.: 18925

TAP CLEARED

LOCATION: N.E. Cor. Acushnet Ave. and Oakley

OWNER:

MEASURES: 3/4

E from	Acushnet	51.0 ft.
S from N line	Oakley	7.0 ft.
W from E line	House	6.4 ft.

3/22/16 main to curb stop

26 ft 3/4" copper tubing

1 ft 3/4" female corp adapter

1 ft gas iron curb stop boxes

1 ft 3/4" curb stop valve

lead worker: Ronald Aguiar DPI

12-19-2018: Lead service line replacement program

Phase 1, Contractor: P. Giosio &amp; Sons inc.

Type: CU, Diameter 1", Water Pressure 45 PSI

Distance from main to curb stop N/A

Distance curb stop to meter 29.1'

Distance from curb face to curb stop 5.0'

Depth of service 4.3'

Curb stop replaced NO: Size 3/4"

Corporation replaced NO: Size 3/4"

Ball valve furnished YES: Size 1"

comments: service for house comes off oakley

3/4" copper to curb stop

Total length of new pipe installed (ft): 29.1

DATE

BEF.

AFT.

REMARKS

## METER. HISTORY

## CHARGE OUTS

[illegible]



TAP CLEARED F 6853 Y

\* LOCATION: 4412Acushnet Ave.

OWNER: Walberg Popp

MEASURES:  $3/4''$

E from Agushnet Ave. 51.0 ft.

S from N line                      Oakley                      7.0 ft.

W from E line                      house                      6.4 ft.


6/29/81: Renewed from main to 1 ft. from main.

1.0 ft.-3/4" copper; 3/4" x 3/4" Fig. 413, 5/8" x 3/4"  
lead-cop. adapt. XXS

12/3/87: Renewed from 1/2' outside curb stop to prop line.

Stock: 5 ft. 3/4" copper tubing 1-3/4" curb stop

1 - Caldwell stop box 2 - 3/4 x 5/8 lead to cop adapt. xxs



## METER HISTORY

## CHARGE OUTS

[illegible]