

APPLICATION No.: 19036

TAP CLEARED

LOCATION: 74-76 Glennon St., S.S., W of Arlington

OWNER: A Carroll

MEASURES:

5/8"

L Lead

W from

Arlington

166.2

N from S line

Glennon

6.4

E from W line

House

14.4

June 2, 1959 Renewed from $\frac{1}{2}$ ft. outside curbstop to $2\frac{1}{2}$ ft.
 inside curb stop 3 ft. of $\frac{3}{4}$ " copper tubing
 2 lbs. wiping solder $\frac{3}{4}$ " cop. to cop. stop, fig 415

Dec. 11, 1952 Repaired leak in inside joint of curb stop
 Renewed from curb stop 1 ft. to a point in sidewalk
 1 ft. of $\frac{3}{4}$ " copper tubing 2# Wiping

5-22-2000 Renewed from main to inside cellar.
 (10 ft. ins. prop. line) Stock: 27 ft. - $\frac{3}{4}$ " Copper
 tubing, 1 - $\frac{3}{4}$ " Curb Stop, 1 - Caldwell Stop Box,
 1 - $\frac{5}{8}$ " x $\frac{3}{4}$ " Fig. 413.

DATE

BEF.

AFT.

REMARKS

955001776

5/22/00 2000 2201019

5-22-2000

Tap reamed

[illegible]

CHARGE OUTS
