

APPLICATION No.: 19037

## TAP CLEARED

LOCATION: 103-5 Princeton N.S. W. of Concord

OWNER: Leon McLanson

MEASURES: 5/8"

W from

S from N line

E from W line

L lead

Concord

Princeton

House

10-7-22

233.4 ft.

7.3 ft.

2.6 ft.

-----  
January 22, 1959 Renewed from 1 ft. outside curb stop to 2 ft.  
inside of curb stop.

3 ft. of 3/4" copper tubing      1 3/4" copper stop  
2 lbs. wiping solder  
-----

Jan. 9, 1986 Repaired leak - broken by Gas Co.  
Renewed from a point 10 ft. N x main to a point 12 ft.  
N x main.

Stock:- 2 ft. - 3/4" copper tubing  
2 - 5/8" x 3/4" lead to copper adapt XS  
-----

4-13-01 Renewed from main to property line. Stock:  
32 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop,  
1 - Caldwell Stop Box, 1 - 5/8"x3/4" lead to cop. adapt.XS  
1 - 5/8"x3/4" Fig. 413.

DATE

BEF.

AFT.

REMARKS

3/23/01

4:30  
pm

2001-120-3431

4-13-01 Tap reamed



[illegible]

## CHARGE OUTS

[illegible]