

APPLICATION No.: 19044

TAP CLEARED

LOCATION: N.W. Cor. 603 Maxfield & Beech

DATE

BEF.

AFT.

REMARKS

OWNER: M.J. O Malley

OK Electric 3-11-99 1999/103421

MEASURES: 3/4"

L lead

10-16-1922

3-11-99 Tap reamed

N from

Maxfield

39.8 ft.

E from W line

Beech

6.9 ft.

S from N line

House

4.1 ft.

Oct. 11, 1974 Renewed from 6" outside curb stop
to property line,

8 ft. - 3/4" Copper tubing 3/4" Curb stop

1 wipe joint Caldwell Stop Box

5/8" x 3/4" lead to cop. adaptor

3-11-99 Renewed from main to inside cellar. (14 ft. ins.
prop. line) Stock: 30 ft. - 3/4" Copper tubing,
1 - Caldwell Stop Box, 1 - 3/4" Curb Stop, 1 - 3/4" x 3/4"
Fig. 413.

8/28/08 west end water main rehab contract #4 perrina constr
renewed service from main to a point 4.5ft stock 4.5ft -1 copper tubing
1-1 corp tap 1-1x 3/4 reducer insp by T. Ives cdm

[illegible]

CHARGE OUTS

[illegible]