

APPLICATION No.: 19063

TAP CLEARED

LOCATION: 217 James St., W.S., S. of Kempton

DATE

BEF.

AFT.

REMARKS

OWNER: Fernando Baccelli

MEASURES:

5/8"

L-lead

Copper

01/01/1922

S from

Kempton

85.8 ft.

E from W line

James

7.2 ft.

N from S line

house

2.6 ft.

Jan. 13, 1971 Renewed  $\frac{1}{2}$  ft. outside curb stop to property line.

$6\frac{1}{2}$  ft. -  $\frac{3}{4}$ " Copper tubing  $\frac{3}{4}$ " Curb Stop  
2 wipe joints

- - -

9/9/08 - Perrina Construction - West End Water Rehab -Contract #4  
Renewed service from main to a point 3 ft inside curb stop

11 ft - 1" copper tubing; 1 - 1" corp. tap; 1 -1" curb stop;  
1 -1" x  $\frac{3}{4}$ " reducer. Inspected by Tim Ives, CDM

-----

3/22/11 letter sent to homeowner, leak at lead ball valve

6/14/11 - City crew renewed water service from curb stop to meter

21 ft-  $\frac{3}{4}$ " copper tubing; 1 - $\frac{5}{8}$ " x  $\frac{3}{4}$ " lead to cop adapt xxs. Foreman: Felix Fernandez

-----

6/7/11 12:00 2011-2307702

[illegible]

## CHARGE OUTS

[illegible]