

26 Water for APPLICATION No.: 19071 1"		TAP CLEARED 82481071			
LOCATION:	S.E. Cor. So. Water & Commercial St.	DATE	BEF.	AFT.	REMARKS ✓
OWNER:					
MEASURES:	1"				
	N from S line Spring 29.9 ft.				
	W from E line So. Water 6.3 ft.				
	S from N line Bldg. 80.0 ft.				
	Tapped in to new main				
	S from S line Commercial 78.6 ft.				
	W from W line Bldg. 6.0 ft.				

April 25, 1969 Service tapped into new 16" main on So. Water St.					
38 ft. 1" copper tubing 1 1" Hays tap					
1 1" curb stop 1 Buffalo stop box					

Nov. 19, 1979: Curb stop leak-Waste Old curb was a stop- and - waste, and it was put in backwards.					
1-1" curb stop					

DEC 2 - 1982 --Renewed from curb stop to inside of wall in Building. 10 ft.-1" copper;					

INACTIVE SER					

[illegible]

CHARGE OUTS

[illegible]