

APPLICATION No.: 19072 6"

LOCATION: S.E. Cor. Water St. & Commercial St.

OWNER: N.B. Boiler & Meh. Co.

*Plumber's Landing*

MEASURES:

6"

*FIRE SUPPLY*

N from S line

E from W line

Tapped into new main.

Darling gate, I. Box

Spring

Water

29.3 ft.

15.0 ft.

April 28, 1969 Renew 6" cast iron pipe from 16" x 6" tee in Water Street easterly to a point 16.3 ft. west from east line of Water Street.

Installed a 6" offset 18" center to the center into the 6" bell of the 16" x 6" tee. Installed a 6" mechanical gate 18.3 ft. west from east line of Water Street. Installed a 6" mechanical sleeve 16.3 ft. west from east line of Water St. connecting the new 6" cast pipe to the existing water pipe. The 6" offset was used to go under the gas pipe.

4 ft. 6" cast iron pipe S & S CL

1 6" Offset 18" center to center

1 6" mechanical gate Darling

1 6" gate box complete (regular)

1 6" mechanical sleeve

# TAP CLEARED

DATE

BEF.

AFT.

REMARKS



[illegible]

## CHARGE OUTS.

[illegible]