

APPLICATION No.: 19074

TAP CLEARED

LOCATION: 959 Foot of Homestead St. at Town Line

OWNER: Town of Acushnet

MEASURES: $\frac{3}{4}$ "

E from

S from N line

E from W line

Ball

Homestead

house

7

5.0 ft.

3.0 ft.

287.4 ft.

~~5.4 ft.~~

3.0 ft.

April 20, 1966 Meter was relocated from the street to inside the cellar. Service was changed from $\frac{5}{8}$ " to $\frac{3}{4}$ " from the curb stop into cellar.

- Meter box had rotted away. Sq. frame & cover returned to shop.

Dec. 5, 1966 Lead joint $\frac{1}{2}$ ft. outside curb stop was leaking. Rewiped joint

April 12, 1966 Renewed service from $\frac{1}{2}$ ft. outside curb stop to inside cellar.

18 $\frac{1}{2}$ ft. - $\frac{3}{4}$ " Copper tubing $\frac{3}{4}$ " cop to cop stop
2# wiping solder $\frac{5}{8}$ " reused corp.

Apr. 6, 1978: Renewed from a point 7 ft. East of hydrant. to 9 ft. E of hydrant. 2 ft. - $\frac{3}{4}$ " copper; 2- $\frac{3}{4}$ " x $\frac{3}{4}$ " lead to copper adapt. XS; 1- $\frac{3}{4}$ " curbstop (old used one)

SEP 4 1981 - Renewed service from the main to the prop. line.

67 ft. - $\frac{3}{4}$ " copper; $\frac{3}{4}$ " curb stop; stop box; $\frac{5}{8}$ " x $\frac{3}{4}$ "

Fig. 413

Renewed

[illegible]

CHARGE OUTS

[illegible]